

REVIEWED FOR CODE COMPLIANCE

DATE: 08/19/22
Project Description: PISCO PERUVIAN CASH BAR
Address: 9344 N. Narcoossee Building Official PL 32827
Project permit number: BLD2022-17276
PERMIT NO: BLD2022-17276

Dear Plan Reviewer:
Accept the following narrative in response to comments issued 08-09-22. Any changes have been clouded and tagged with revision 12.
ADDRESS: 9344 NARCOOSSEE RD
CONTRACTOR: SHREY PATEL

Fire:

NOTE: Stanley Kuczynski
E: Permit issuance does not grant permission
stanley.kuczynski@cityoforlando.net Corrections Required
to violate applicable codes
CONTACT INFO: For questions regarding fire plans review, please contact (Stosh) Stanley Kuczynski at 407-246-3770 or
E-Mail: Stanley.Kuczynski@cityoforlando.net. PLAN REVIEW STATUS:
Comment: Low metal stud wall is not shown in the Life Safety Plan.
Comment: Life safety plan does not match floor plan.

PERMITTING SERVICES DIVISION

Response: The dashed lines shown in the floor plan and in question indicates the header above. There is no low wall at that location. Those lines have been removed from this plan. Now the plan matches the Life Safety Plan. .

Note that I'm including the Life Safety Plan sheet A0.1 in this resubmittal because some dimensions have been added, the emergency lights and signs are now shown, and the table layout at the outdoor patio have been revised.

If there if any question, I can be contacted at phone number (407) 375-0209.
Sincerely,

Rafael A Carbone

Rafael A. Carbone, RA